



PIPE I.D.	WALL THK.	NOM. JOINT DIAMETER	JOINT DEPTH	BELL OUTSIDE DIA.	'X'
30"Ø	3 1/2"	35 5/8"Ø	4 5/8"	42 1/4"Ø	2 1/2"
30"Ø	4 1/4"	35 5/8"Ø	4 5/8"	42 1/4"Ø	2 1/2"
36"Ø	4"	42 3/8"Ø	4 7/8"	50 1/4"Ø	2 1/2"
36"Ø	4 3/4"	42 3/8"Ø	4 7/8"	50 1/4"Ø	2 1/2"
42"Ø	4 1/2"	49 5/16"Ø	5 1/4"	58"Ø	2 1/2"
42"Ø	5 1/4"	49 5/16"Ø	5 1/4"	58"Ø	2 1/2"
48"Ø	5"	55 5/16"Ø	5 1/2"	64"Ø	2 1/2"
48"Ø	5 3/4"	55 5/16"Ø	5 1/2"	64"Ø	2 1/2"
54"Ø	5 1/2"	61 5/16"Ø	5 1/2"	70"Ø	2 1/2"

PIPE I.D.	WALL THK.	NOM. JOINT DIAMETER	JOINT DEPTH	BELL OUTSIDE DIA.	'X'
54"Ø	6 1/4"	61 5/16"Ø	5 1/2"	70"Ø	2 1/2"
60"Ø	6"	67 5/16"Ø	5 1/2"	76"Ø	2 1/2"
60"Ø	6 3/4"	67 5/16"Ø	5 1/2"	76"Ø	2 1/2"
66"Ø	6 1/2"	73 5/16"Ø	5 1/2"	82"Ø	2 1/2"
66"Ø	7 1/4"	73 5/16"Ø	5 1/2"	82"Ø	2 1/2"
72"Ø	7"	79 5/16"Ø	5 1/2"	88"Ø	2 1/2"
72"Ø	8"	79 5/16"Ø	5 1/2"	88"Ø	2 1/2"
78"Ø	8 1/4"	84 5/8"Ø	5 1/2"	94 1/2"Ø	2 1/2"
84"Ø	8"	91 1/16"Ø	5 3/4"	100"Ø	2 3/4"
84"Ø	8 3/4"	91 1/16"Ø	5 3/4"	101 1/2"Ø	2 3/4"

MATERIALS:

CONCRETE: 4,000 PSI MIN. TYPE I/II CEMENT
 CONFORMS TO ASTM C76 & AASHTO M170
 JOINT CONFORMS TO ASTM C443 & C1619

NOTES:

AVAILABLE IN CLASS III, IV & V
 NOMINAL JOINT LENGTHS ARE 12'



REINFORCED CONCRETE PIPE

VIHY - SINGLE OFFSET JOINT 30"Ø TO 84"Ø

3.X